

Consortium for Electric Reliability Technology Solutions

Research Overview

LBNL Physics Division

21 May 2010

Joseph H. Eto
CERTS Program Office
Lawrence Berkeley National Laboratory



Electric Grid Problems are Costly

- **Blackouts** – 2003 Northeast Blackout cost \$5-10 billion
- **Congestion**
 - Annual cost estimated to be several billion dollars
 - DOE's 2006 National Electric Transmission Congestion Study indicated that "transmission congestion always has a cost."
- **Market Dysfunction** – 2001 California electricity crises cost California consumers billions of dollars
- **Power Quality and Reliability** – Inadequate power quality and reliability costs businesses \$50 to \$100 billion annually
- **Market Inefficiency** – Higher LMP, redispatch, and market power result in higher consumer costs




Need Transmission Investments – Upgrade Existing Grid, Expand Infrastructure, Research and Demonstrate New Technologies, and Modernize Grid with Monitoring, Visualization, and Digital Technologies



In 2004, LBNL Estimated That Power Interruptions Cost the Nation ~\$79 B/yr

Yet, LBNL Also Found Significant Uncertainties in the Data



Source: Hamachi-LaCommare, K, and J. Eto. *Understanding the Cost of Power Interruptions to U.S. Electricity Customers*. July, 2004. LBNL-55718

<http://certs.lbl.gov/certs-rtina-pubs.html>




Consortium for Electric Reliability Technology Solutions

- CERTS was organized in 1999 as a partnership among universities, the private sector, and Department of Energy national labs. Consortium includes four labs (Lawrence Berkeley, Oak Ridge, Sandia, Pacific Northwest), Power Systems Engineering Research Center (consortium of universities led by Arizona State), and Electric Power Group.
- CERTS Industry Advisory Board includes ISOs, utilities, regulators, generators.
- CERTS research leverages public and private resources, including funding by the Department of Energy, Office of Electricity Delivery and Energy Reliability, Transmission Reliability Program, and the California Energy Commission, Public Interest Energy Research Program.
- CERTS research is focused on addressing gaps in tools, technologies, systems, market rules, and management processes needed to manage the reliability of the electric grid and efficient market operations.



Grid Solutions Framework and CERTS Research Focus

Grid Solutions Framework



Research Focus 1:









Reliability Metrics and Compliance Monitoring Tools

Visualization, Compliance, Monitoring, Infrastructure, Real Time Wide-Area Standards Compliance and Situational Awareness

- | | | | | | |
|--|---|---|--|--|--|
| <ul style="list-style-type: none"> • 1999 Low Frequency Events on Eastern Interconnection • Declining System Performance • Frequency Excursions | <ul style="list-style-type: none"> • Wide-area visualization infrastructure • Relational time-series database | <ul style="list-style-type: none"> • Wide-area real time ACE-Frequency monitoring tool • Suppliers performance for AGC and frequency response | <ul style="list-style-type: none"> • Interchange Error (AIE) Monitoring • Wide-area Inadvertent Monitoring | <ul style="list-style-type: none"> • Performance standards research, validation, field trials • Resources adequacy load-generation analysis and assessment | <ul style="list-style-type: none"> • CPS-BAAL monitoring and analysis • Research for situational awareness for resource adequacy |
|--|---|---|--|--|--|

GOAL

Common Wide-Area, Real Time Monitoring Platform – Standards Compliance, Key Metrics for Reliability Intelligent Alarms, Reports, and Event Analysis Situation Awareness Visualization Dashboards for NERC, DOE, and FERC



PROBLEM IDENTIFICATION

INFRASTRUCTURE DESIGN

VISUALIZATION

WIDE-AREA MONITORING

FORENSIC ANALYSIS


COMPLIANCE MONITORING



CERTS
 CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

Applications Architecture

(1) DATA ACQUISITION



Typical Use for Root Cause Identification – ACE-Frequency Application

A

Act on Early Warning
Intelligent Alarms

Subject Line

High Frequency Trigger Limit Violation 60.055 Hz


Message

FTL HIGH: -EAST 8/23/2005 11:34:00 PM (EDT)
Frequency has reached/or exceeded FTL of 60.05 Hz.
for more than 5 minutes.

Load-Generation resources under inadequate balance.


B

Select Jurisdiction (s)
Violating Performance
Metric Threshold Now




C

Identify Control Areas
Contributing to
Jurisdiction Violation
Now in Last 30-Minutes



D

Zoom-In and Evaluate
Magnitude and Duration
of Problem For Worst
Control Areas



Research Focus 2:

North American SynchroPhasor Initiative






Phasor Measurements, Real Time Wide-Area Situational Awareness, Visualization, Infrastructure, Monitoring, Alarming, and Control

| | | | | | |
|---|---|--|---|---|--|
| <ul style="list-style-type: none"> • 1996 Western Interconnection Blackouts • 2003 Northeast Blackout | <ul style="list-style-type: none"> ▪ TVA Super PDC ▪ IEEE 37.118 ▪ NIST SynchroLab | <ul style="list-style-type: none"> • Real Time Dynamics Monitoring System | <ul style="list-style-type: none"> • CAISO Operating Engineers Workstation • Baseline Static Angles in East | <ul style="list-style-type: none"> • Small Signal Stability Monitoring ▪ Intelligent Alarming ▪ State Estimation ▪ Adaptive Islands | <ul style="list-style-type: none"> ▪ EIPP -> NASPI ▪ WECC WAMTF ▪ Research Roadmap |
|---|---|--|---|---|--|

GOAL

Industry Approach to Phasor Technology Research and Applications:

- Visualization
- State Estimation
- Mode Monitoring
- Alarming
- Real Time Controls



PROBLEM IDENTIFICATION

INFRASTRUCTURE DEVELOPMENT

VISUALIZATION FOR WIDE-AREA SITUATIONAL AWARENESS

FORENSIC ANALYSIS/ BASELINING

APPLICATIONS

INDUSTRY ADOPTION




CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

Inaccurate Dynamic Models were a Cause of the WECC 1996 Breakup

Actual System Performance

- unstable system behavior observed.




Model Simulation

- predicted stable system performance.



Lack of Wide-Area Visibility Was a Cause of the EI Aug 14th, 2003 Blackout



Phase Angles Diverged Prior To Blackout



Source: www.nerc.com
Angles are based on data from blackout analysis.
Angle reference is Browns Ferry.

Phasor Technologies Give Operators *MRI-like* Visibility of Power Systems

| ATTRIBUTE | Traditional Grid Monitoring (SCADA) | PHASOR Technologies |
|---|---|--|
| Resolution | 1 sample every 2-4 seconds | 10-120 samples per second |
| Measured Quantities | Magnitude Only | Magnitude & Phase Angle |
| Time Synchronization | No | Yes |
| Focus | Control Area (Local) monitoring & control | Wide area (interconnection) monitoring & control |
| Observability | Steady state only | Steady state, dynamic and transients |
| Monitoring Angles, Damping, Frequency Response, & Other Metrics | No | Yes |
| Oscillation Detection | No | Yes |

Phasor technology is *NOT* a replacement for SCADA,
rather it *complements* existing SCADA systems




WESTERN INTERCONNECTION

– EXISTING PMUs

– NEW & PROPOSED PMUs


GOAL – ALL 500 KV SUBSTATIONS, RENEWABLES AND KNOWN CONGESTION POINTS



Visualization – “Dashboard” Display

Visualization Tiers – Dashboard, Interconnection, Reliability Coordinator, Local Area

Real Time Alarms within
ALL
RTDMS Client Applications



Research Focus 3:





Science-Based Analysis of Market Designs and Real-Time Market Monitoring Tools

Engineering Design Tools, Market Simulation, Real-Time Market Monitoring Tools

| | | | | | |
|--|--|--|---|---|--|
| <ul style="list-style-type: none"> • Eastern ISO Price Spikes 1999 • Western Market Meltdown 2000-2001 | <ul style="list-style-type: none"> ▪ Experimental economics power system market simulation platform | <ul style="list-style-type: none"> ▪ Auction design evaluations ▪ Effects of demand response | <ul style="list-style-type: none"> ▪ VAR and real power markets ▪ Co-optimization of real and reserve power markets | <ul style="list-style-type: none"> ▪ Revenue sensitivity ▪ Real-time market monitoring prototype tool | <ul style="list-style-type: none"> ▪ Super OPF design studies |
|--|--|--|---|---|--|

GOAL

A Complete Network Optimization Tool for Organized Markets, and Supporting Real-Time Market Monitoring Tools for Market Operators and FERC0



Tools that optimally dispatch and correctly price:

- Real energy
- VARs
- Real power reserves
- Dynamic reactive reserves
- Voltage

PROBLEM IDENTIFICATION

MARKET ANALYSIS INFRASTRUCTURE

MARKET DESIGN EVALUATION

INCORPORATING NETWORK PROPERTIES


MARKET MONITORING TOOLS

COMPLETE OPTIMIZATION OF MARKET DESIGN




Can Operators Predict Market Behavior?

Traditional Operations



- Powerplants dispatched in order of increasing costs
- Strong correlation between power flow on lines and total electricity demand
- Reliable system operation can be scheduled in advance



Market-based Operations



- Powerplants dispatched by market participants seeking profits
- Poor correlation between power flow on lines and total electricity demand
- Reliable system operation more difficult to schedule - requires better predictive tools



Science-Based Analysis of Electricity Market Designs and Operation



Research Focus 4:





Demand Response or Load As A Resource

Capability Building, Demonstrations, Policy Changes, Enhanced Values

| | | | | | |
|---|--|---|---|---|---|
| <ul style="list-style-type: none"> • Price Spikes • Supplier Market Power • Inelastic Demand | <ul style="list-style-type: none"> ▪ Technology review ▪ Ancillary services review | <ul style="list-style-type: none"> ▪ Program design and evaluations for leading ISO demand response program (NYISO, ISO NE, PJM) | <ul style="list-style-type: none"> ▪ Provision of spinning reserve with aggregated demand-side resources | <ul style="list-style-type: none"> ▪ NERC Policy 10 revisions to allow for demand response ▪ WECC CMOPS and MORCWG policy changes | <ul style="list-style-type: none"> ▪ Quantify unique system values of Demand Response – speed of response, geographic targeting ▪ Market power mitigation |
|---|--|---|---|---|---|

GOAL

Meaningful Demand-Side Participation in Competitive Wholesale Markets for Energy and Ancillary Services



PROBLEM
IDENTIFICATION

TECHNOLOGY
REQUIREMENTS

TECHNICAL
SUPPORT/
CAPABILITY
BUILDING

DEMON-
STRATIONS

INSTITUTIONAL
CHANGE





EFFICIENT
DEMAND-SIDE
MARKET
PARTICIPATION




CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

There Are Five Basic Types of Responsive Load

1. **Energy Efficiency** programs reduce overall electricity consumption, generally also at times of peak demand
2. **Price Response** programs move consumption from times of high prices to times of lower prices (real time pricing or time of use)
3. **Peak Shaving** programs require more response during peak hours and focus on reducing peaks on high-system load days
4. **Reliability Response** (contingency response) requires the fastest, shortest duration response. Response is only required during power system “events.” – This is new and slowly developing.
5. **Regulation Response** continuously follows minute-to-minute commands from the grid in order to balance the aggregate system load and generation – This is also very new and appears to be very promising for certain loads.




Contingency Reserves Restore System Frequency Immediately After Loss of Generation



2009 PG&E Test System

SmartAC Ancillary Services Pilot 2009



PG&E Real Time Display

EICT / FSC / PGE Pilot

Refresh Pause

Overview

Antioch

Fairfield

Fresno 1

Fresno 2

Control

Friday 04 September 2009

Updated: 02:30 PM

Feeder - Actual vs Forecast



Premise - Extrapolation vs Forecast




Sample Statistics



Monitored Load

Units: 129
Total Load: 175.92 kW
Baseline: 136.20 kW
Reduction: 107.28 kW
Projected Trendline
Baseline: -- kW
Reduction: -- kW

Actual A/C Units On



Extrapolated Load

Units: 526
Total Load: 0.69 MW
Baseline: 0.52 MW
Reduction: 0.43 MW
Projected Trendline
Baseline: -- MW
Reduction: -- MW



Research Focus 5:




Distributed Energy Resource Microgrids

Tool Development, Simulation, Bench-Scale Testing,
Full-Scale Test Bed, and Value Engineering

| | | | | | |
|--|-------------------|---|--|---|------------------------------|
| <ul style="list-style-type: none"> Customer demand for reliability and power quality Grid integration concerns | Microgrid Concept | <ul style="list-style-type: none"> muGrid DER-Customer Adoption Model | <ul style="list-style-type: none"> Simulation analysis Laboratory bench-scale tests Test bed design | <ul style="list-style-type: none"> American Electric Power Test Bed IEEE 1547.4 | Lower cost of key components |
|--|-------------------|---|--|---|------------------------------|

GOAL

A Peer-to-Peer, Plug-and-Play Design That Minimizes Custom Engineering and Presents Clusters of DER to Grid as Controllable Loads – Good and Model Citizens of the Grid



PROBLEM
IDENTIFICATION

CONCEPTUAL
DESIGN

ANALYTIC
TOOL
DEVELOPMENT

PROOF OF
CONCEPT

FULL-SCALE
TEST BED

STANDARDIZED
ENGINEERING
DESIGNS



CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

Microgrids vs. CERTS Microgrids

“A microgrid is an integrated energy system consisting of interconnected loads and distributed energy resources which as an integrated system can operate in parallel with the grid or in an intentional island mode”

Microgrids Research Assessment prepared by
Navigant Consulting for DOE and CEC. May 2006

Distinguishing features of the **CERTS Microgrid *Concept***

- Seamless islanding and reconnection via single PCC
- Peer-to-peer, autonomous coordination among micro-sources
- Plug-and-play - no custom engineering

Distinguishing features of the **CERTS Microgrid *Test Bed Demonstration***

- Small sources (<100 kW each)
- No stand-alone storage (yet)
- No power flow onto the grid




AEP/CERTS Microgrid test site



60 kW
Sources

Static
Switch



Loads



Research Focus 6:






Reliability Technology Issues and Needs Assessment

Technology Scoping, Analytical Studies, DOE Analysis Support

| | | | | | |
|---|---|--|---|---|---|
| <ul style="list-style-type: none"> • Blackouts, Declining Reliability • Increased Transmission Congestion • Inadequate Transmission Investment | <ul style="list-style-type: none"> • Grid of the Future White Papers • Real-time tools assessment • Grid metrics | <ul style="list-style-type: none"> • Cost of power interruptions to US • Review of US congestion costs • Transmission cost allocation | <ul style="list-style-type: none"> • Renewable operational integration • Transmission planning R&D needs • Event reporting | <ul style="list-style-type: none"> • 1999 Power Outage Study Team • 2003 Blackout Investigation | <ul style="list-style-type: none"> • 2002 National Transmission Grid Study • 2006 and 2009 DOE Congestion Studies |
|---|---|--|---|---|---|

GOAL

Science-based, technical analysis of reliability technology and policy issues to inform decision-makers



PROBLEM IDENTIFICATION

TECHNOLOGY SCOPING

ECONOMIC ASSESSMENT

TECHNICAL ASSESSMENT


BLACKOUT INVESTIGATION

NATIONAL POLICY STUDIES



CERTS
CONSORTIUM FOR ELECTRIC RELIABILITY TECHNOLOGY SOLUTIONS

Renewable Electricity Generation Resources Are Sometimes Located Far From Load Centers



Source: DOE National Electric Transmission Congestion Study

Wind is an *Intermittent* Resource; However, It Is Also a *Predictable* Resource

Tehachapi Wind Generation in April – 2005 Source: CAISO

